

Correction Factor for Supercooling

Correction factors shown here indicate changes in capacity depending on the degree of supercooling caused by low-stage side high-pressure solution refrigerant in the two-stage compression-type refrigerating device, and heat exchange attachment device, etc. For devices with a significant degree of supercooling, the figure shown in the capacity table multiplied by the correction factor shown in the table below is the capacity of the expansion valve.

R134a

Condensing Temp (°C)	Sub-cooling ΔT							
	0	10	20	30	40	50	60	70
0	1.00	1.10	1.20	1.30	-	-	-	-
10	1.00	1.11	1.22	1.33	1.45	-	-	-
20	1.00	1.12	1.25	1.37	1.50	1.62	-	-
30	1.00	1.14	1.28	1.42	1.56	1.70	1.85	-
38	1.00	1.15	1.31	1.47	1.63	1.79	1.95	2.11
40	1.00	1.16	1.32	1.48	1.65	1.81	1.98	2.14
50	1.00	1.19	1.38	1.57	1.76	1.96	2.15	2.35
60	1.00	1.23	1.46	1.70	1.93	2.17	2.41	2.65

R404A

Condensing Temp (°C)	Sub-cooling ΔT							
	0	10	20	30	40	50	60	70
0	1.00	1.13	1.26	1.39	-	-	-	-
10	1.00	1.15	1.29	1.44	1.59	-	-	-
20	1.00	1.17	1.34	1.51	1.69	1.86	-	-
30	1.00	1.20	1.41	1.62	1.82	2.03	2.24	-
38	1.00	1.24	1.49	1.73	1.98	2.23	2.48	2.73
40	1.00	1.26	1.51	1.77	2.03	2.29	2.55	2.82
50	1.00	1.35	1.70	2.04	2.39	2.74	3.09	3.45
60	1.00	1.56	2.11	2.65	3.19	3.74	4.28	4.84

R407C

Condensing Temp (°C)	Sub-cooling ΔT							
	0	10	20	30	40	50	60	70
0	1.00	1.10	1.21	1.31	-	-	-	-
10	1.00	1.11	1.23	1.34	1.46	-	-	-
20	1.00	1.13	1.26	1.38	1.51	1.65	-	-
30	1.00	1.15	1.29	1.44	1.59	1.73	1.88	-
38	1.00	1.16	1.33	1.49	1.66	1.83	2.00	2.17
40	1.00	1.17	1.34	1.51	1.68	1.86	2.03	2.21
50	1.00	1.21	1.41	1.62	1.82	2.03	2.24	2.45
60	1.00	1.26	1.53	1.79	2.05	2.31	2.57	2.83

R410A

Condensing Temp (°C)	Sub-cooling ΔT							
	0	10	20	30	40	50	60	70
0	1.00	1.11	1.21	1.32	-	-	-	-
10	1.00	1.12	1.24	1.36	1.48	-	-	-
20	1.00	1.14	1.27	1.41	1.54	1.68	-	-
30	1.00	1.16	1.32	1.47	1.63	1.79	1.94	-
38	1.00	1.18	1.36	1.54	1.72	1.90	2.08	2.27
40	1.00	1.19	1.38	1.57	1.75	1.94	2.13	2.32
50	1.00	1.25	1.48	1.72	1.95	2.18	2.42	2.65
60	1.00	1.36	1.70	2.02	2.34	2.66	2.98	3.29

R448A

Condensing Temp (°C)	Sub-cooling ΔT							
	0	10	20	30	40	50	60	70
0	1.00	1.09	1.18	1.27	-	-	-	-
10	1.00	1.10	1.20	1.30	1.40	-	-	-
20	1.00	1.12	1.23	1.34	1.46	1.57	-	-
30	1.00	1.13	1.27	1.40	1.52	1.65	1.78	-
38	1.00	1.15	1.30	1.45	1.60	1.74	1.88	2.03
40	1.00	1.16	1.32	1.47	1.62	1.77	1.91	2.06
50	1.00	1.20	1.39	1.57	1.76	1.94	2.12	2.29
60	1.00	1.26	1.51	1.75	1.99	2.22	2.45	2.67

R449A

Condensing Temp (°C)	Sub-cooling ΔT							
	0	10	20	30	40	50	60	70
0	1.00	1.09	1.18	1.28	-	-	-	-
10	1.00	1.10	1.21	1.31	1.41	-	-	-
20	1.00	1.12	1.23	1.35	1.46	1.57	-	-
30	1.00	1.14	1.27	1.40	1.53	1.66	1.79	-
38	1.00	1.16	1.31	1.46	1.60	1.75	1.89	2.04
40	1.00	1.16	1.32	1.47	1.63	1.78	1.93	2.07
50	1.00	1.20	1.39	1.58	1.77	1.95	2.13	2.31
60	1.00	1.27	1.52	1.77	2.01	2.25	2.48	2.71

AEX Capacity table

R23

Extreme low temp. <-100~ -70°C> Superheat change 5°C

Catalog No.		evaporating temp. (°C)	Capacity (U.S.R.T.) {kW}			
			Condensing temp. (°C)			
Type	Model		-20	-30	-40	-50
AEX-	2333BCZ	-70	0.32 {1.13}	0.30 {1.05}	0.26 {0.93}	0.22 {0.77}
		-75	0.26 {0.92}	0.24 {0.86}	0.22 {0.78}	0.18 {0.65}
		-80	0.22 {0.79}	0.22 {0.76}	0.20 {0.69}	0.17 {0.59}
		-85	0.20 {0.69}	0.18 {0.65}	0.17 {0.59}	0.15 {0.52}
		-90	0.16 {0.56}	0.15 {0.53}	0.14 {0.49}	0.12 {0.43}
		-95	0.14 {0.49}	0.13 {0.45}	0.12 {0.42}	0.11 {0.37}
		-100	0.12 {0.41}	0.11 {0.38}	0.10 {0.35}	0.09 {0.31}
	2335BCZ 2345BCZ	-70	0.64 {2.24}	0.59 {2.09}	0.53 {1.86}	0.43 {1.52}
		-75	0.52 {1.83}	0.49 {1.72}	0.44 {1.55}	0.37 {1.30}
		-80	0.45 {1.58}	0.43 {1.50}	0.39 {1.36}	0.33 {1.17}
		-85	0.39 {1.37}	0.37 {1.29}	0.34 {1.19}	0.29 {1.03}
		-90	0.32 {1.12}	0.30 {1.06}	0.28 {0.97}	0.24 {0.85}
		-95	0.28 {0.97}	0.26 {0.91}	0.24 {0.84}	0.21 {0.73}
		-100	0.23 {0.81}	0.22 {0.76}	0.20 {0.70}	0.18 {0.62}
	2348BCZ	-70	0.94 {3.30}	0.88 {3.09}	0.78 {2.74}	0.64 {2.26}
		-75	0.79 {2.79}	0.75 {2.62}	0.67 {2.35}	0.57 {1.99}
		-80	0.70 {2.45}	0.66 {2.31}	0.60 {2.10}	0.53 {1.85}
		-85	0.60 {2.10}	0.57 {1.99}	0.51 {1.81}	0.45 {1.58}
		-90	0.50 {1.76}	0.47 {1.66}	0.43 {1.51}	0.38 {1.34}
		-95	0.43 {1.51}	0.41 {1.43}	0.37 {1.30}	0.33 {1.15}
		-100	0.35 {1.22}	0.32 {1.14}	0.30 {1.05}	0.26 {0.92}
	2341BCZ	-70	1.40 {4.93}	1.31 {4.62}	1.16 {4.09}	0.96 {3.36}
		-75	1.19 {4.19}	1.12 {3.93}	1.00 {3.53}	0.85 {2.99}
		-80	1.04 {3.66}	0.98 {3.45}	0.89 {3.13}	0.77 {2.70}
		-85	0.87 {3.06}	0.82 {2.90}	0.75 {2.64}	0.65 {2.30}
		-90	0.73 {2.55}	0.69 {2.41}	0.63 {2.20}	0.55 {1.93}
		-95	0.63 {2.21}	0.59 {2.09}	0.55 {1.92}	0.48 {1.69}
		-100	0.53 {1.87}	0.50 {1.76}	0.46 {1.60}	0.40 {1.41}
	2342BCZ	-70	2.42 {8.51}	2.27 {7.98}	2.01 {7.07}	1.65 {5.80}
		-75	2.06 {7.23}	1.93 {6.79}	1.73 {6.10}	1.47 {5.16}
		-80	1.78 {6.27}	1.68 {5.92}	1.53 {5.37}	1.32 {4.63}
		-85	1.56 {5.50}	1.48 {5.21}	1.35 {4.76}	1.18 {4.15}
		-90	1.28 {4.51}	1.21 {4.27}	1.11 {3.91}	0.98 {3.43}
		-95	1.09 {3.83}	1.03 {3.62}	0.94 {3.30}	0.83 {2.92}
		-100	0.90 {3.15}	0.84 {2.97}	0.77 {2.71}	0.68 {2.38}
	2344BCZ 3454BCZ 4564BCZ	-70	4.10 {14.4}	3.87 {13.6}	3.41 {12.0}	2.80 {9.86}
		-75	3.50 {12.3}	3.27 {11.5}	2.96 {10.4}	2.49 {8.77}
		-80	3.04 {10.7}	2.87 {10.1}	2.61 {9.16}	2.25 {7.91}
		-85	2.60 {9.13}	2.46 {8.64}	2.24 {7.87}	1.95 {6.87}
		-90	2.18 {7.65}	2.06 {7.24}	1.89 {6.63}	1.66 {5.83}
		-95	1.85 {6.50}	1.75 {6.14}	1.60 {5.62}	1.41 {4.95}
		-100	1.54 {5.43}	1.46 {5.12}	1.33 {4.66}	1.17 {4.10}
	4566BCZ	-70	5.66 {19.9}	5.29 {18.6}	4.69 {16.5}	3.87 {13.6}
		-75	4.81 {16.9}	4.49 {15.8}	4.04 {14.2}	3.44 {12.1}
		-80	4.18 {14.7}	3.92 {13.8}	3.58 {12.6}	3.07 {10.8}
		-85	3.58 {12.6}	3.38 {11.9}	3.07 {10.8}	2.69 {9.45}
		-90	2.99 {10.5}	2.84 {9.99}	2.60 {9.13}	2.28 {8.02}
		-95	2.53 {8.90}	2.39 {8.41}	2.19 {7.69}	1.93 {6.78}
		-100	2.06 {7.23}	1.93 {6.80}	1.77 {6.21}	1.56 {5.47}
	4568BCZ	-70	7.54 {26.5}	7.05 {24.8}	6.26 {22.0}	5.12 {18.0}
		-75	6.37 {22.4}	5.97 {21.0}	5.40 {19.0}	4.55 {16.0}
		-80	5.60 {19.7}	5.26 {18.5}	4.75 {16.7}	4.10 {14.4}
		-85	4.75 {16.7}	4.49 {15.8}	4.10 {14.4}	3.58 {12.6}
		-90	4.01 {14.1}	3.78 {13.3}	3.44 {12.1}	3.04 {10.7}
		-95	3.33 {11.7}	3.13 {11.0}	2.87 {10.1}	2.53 {8.91}
		-100	2.82 {9.90}	2.65 {9.31}	2.41 {8.49}	2.13 {7.48}

R134a

Standard <-30~10°C> Superheat change 5°C

Catalog No.		evaporating temp. (°C)	Capacity (U.S.R.T.) {kW}			
			Condensing temp. (°C)			
Type	Model		25	38	50	60
AEX-	2333BM	10	0.35 {1.22}	0.44 {1.54}	0.48 {1.68}	0.48 {1.68}
		0	0.34 {1.19}	0.39 {1.36}	0.40 {1.42}	0.40 {1.39}
		-5	0.32 {1.14}	0.36 {1.27}	0.37 {1.30}	0.36 {1.27}
		-10	0.31 {1.08}	0.34 {1.18}	0.34 {1.21}	0.33 {1.16}
		-20	0.25 {0.89}	0.27 {0.94}	0.27 {0.94}	0.26 {0.90}
		-30	0.17 {0.61}	0.18 {0.64}	0.18 {0.63}	0.17 {0.60}
	2335BM 2345BM	10	0.69 {2.43}	0.88 {3.08}	0.95 {3.35}	0.95 {3.35}
		0	0.67 {2.37}	0.77 {2.72}	0.80 {2.83}	0.79 {2.78}
		-5	0.65 {2.28}	0.72 {2.53}	0.74 {2.60}	0.72 {2.53}
		-10	0.61 {2.16}	0.67 {2.36}	0.69 {2.41}	0.66 {2.31}
		-20	0.50 {1.77}	0.53 {1.88}	0.53 {1.88}	0.51 {1.79}
		-30	0.35 {1.22}	0.36 {1.27}	0.36 {1.26}	0.34 {1.20}
	2348BM	10	1.04 {3.66}	1.32 {4.64}	1.43 {5.03}	1.44 {5.05}
		0	1.02 {3.60}	1.17 {4.13}	1.22 {4.30}	1.20 {4.22}
		-5	0.99 {3.47}	1.10 {3.87}	1.13 {3.98}	1.10 {3.87}
		-10	0.93 {3.28}	1.02 {3.58}	1.04 {3.64}	1.00 {3.52}
		-20	0.76 {2.66}	0.81 {2.84}	0.81 {2.84}	0.77 {2.72}
		-30	0.61 {2.15}	0.64 {2.26}	0.63 {2.23}	0.60 {2.12}
	2341BM	10	1.49 {5.23}	1.89 {6.63}	2.04 {7.19}	2.05 {7.21}
		0	1.42 {5.00}	1.62 {5.71}	1.69 {5.95}	1.66 {5.85}
		-5	1.35 {4.73}	1.50 {5.28}	1.54 {5.41}	1.50 {5.28}
		-10	1.25 {4.41}	1.37 {4.81}	1.39 {4.90}	1.35 {4.73}
		-20	1.04 {3.65}	1.10 {3.88}	1.10 {3.88}	1.06 {3.72}
		-30	0.70 {2.45}	0.73 {2.57}	0.73 {2.55}	0.69 {2.42}
	2342BM	10	2.54 {8.93}	3.21 {11.3}	3.50 {12.3}	3.50 {12.3}
		0	2.46 {8.65}	2.82 {9.90}	2.93 {10.3}	2.87 {10.1}
		-5	2.33 {8.21}	2.60 {9.14}	2.67 {9.40}	2.60 {9.15}
		-10	2.18 {7.66}	2.38 {8.37}	2.42 {8.51}	2.34 {8.24}
		-20	1.76 {6.20}	1.87 {6.59}	1.87 {6.59}	1.79 {6.31}
		-30	1.20 {4.21}	1.25 {4.41}	1.24 {4.37}	1.18 {4.15}
	2344BM 3454BM 4564BM	10	4.27 {15.0}	5.40 {19.0}	5.86 {20.6}	5.86 {20.6}
		0	4.10 {14.4}	4.69 {16.5}	4.89 {17.2}	4.86 {17.1}
		-5	3.98 {14.0}	4.41 {15.5}	4.52 {15.9}	4.41 {15.5}
		-10	3.70 {13.0}	4.04 {14.2}	4.10 {14.4}	4.01 {14.1}
		-20	2.99 {10.5}	3.19 {11.2}	3.19 {11.2}	3.04 {10.7}
		-30	2.01 {7.08}	2.11 {7.42}	2.09 {7.35}	1.99 {6.99}
	4566BM	10	6.97 {24.5}	8.87 {31.2}	9.58 {33.7}	9.61 {33.8}
		0	6.85 {24.1}	7.85 {27.6}	8.16 {28.7}	8.05 {28.3}
		-5	6.48 {22.8}	7.20 {25.3}	7.37 {25.9}	7.20 {25.3}
		-10	5.97 {21.0}	6.57 {23.1}	6.65 {23.4}	6.46 {22.7}
		-20	5.23 {18.4}	5.60 {19.7}	5.60 {19.7}	5.32 {18.7}
		-30	3.27 {11.5}	3.44 {12.1}	3.41 {12.0}	3.24 {11.4}
	4568BM	10	8.76 {30.8}	10.5 {36.9}	11.4 {40.0}	11.4 {40.1}
		0	8.76 {30.8}	10.0 {35.3}	10.4 {36.7}	10.3 {36.2}
		-5	8.59 {30.2}	9.58 {33.7}	9.87 {34.7}	9.58 {33.7}
		-10	8.36 {29.4}	9.13 {32.1}	9.30 {32.7}	8.96 {31.5}
		-20	7.14 {25.1}	7.59 {26.7}	7.59 {26.7}	7.28 {25.6}
		-30	5.35 {18.8}	5.63 {19.8}	5.60 {19.7}	5.29 {18.6}

Catalog No.		evaporating temp. (°C)	Capacity (U.S.R.T.) {kW}			
			Condensing temp. (°C)			
Type	Model		25	38	50	60
AEX-	2333BU	10	0.37 {1.31}	0.44 {1.54}	0.41 {1.43}	0.32 {1.14}
		0	0.37 {1.30}	0.38 {1.34}	0.34 {1.19}	0.26 {0.91}
		-5	0.34 {1.20}	0.34 {1.20}	0.31 {1.10}	0.22 {0.79}
		-10	0.31 {1.09}	0.30 {1.06}	0.26 {0.91}	0.19 {0.67}
		-20	0.24 {0.86}	0.23 {0.80}	0.19 {0.66}	0.13 {0.47}
		-30	0.18 {0.62}	0.16 {0.57}	-	-
		-40	0.12 {0.42}	0.11 {0.37}	-	-
AEX-	2335BU	10	0.74 {2.61}	0.87 {3.07}	0.81 {2.84}	0.65 {2.27}
		0	0.74 {2.60}	0.76 {2.67}	0.67 {2.37}	0.51 {1.80}
		-5	0.68 {2.39}	0.68 {2.39}	0.62 {2.18}	0.45 {1.57}
		-10	0.62 {2.17}	0.60 {2.11}	0.51 {1.80}	0.38 {1.33}
		-20	0.48 {1.70}	0.46 {1.60}	0.37 {1.30}	0.26 {0.93}
		-30	0.35 {1.23}	0.32 {1.13}	-	-
		-40	0.24 {0.84}	0.21 {0.75}	-	-
AEX-	2345BU	10	1.17 {4.11}	1.37 {4.80}	1.26 {4.44}	1.00 {3.53}
		0	1.14 {4.02}	1.18 {4.16}	1.04 {3.65}	0.80 {2.81}
		-5	1.04 {3.65}	1.05 {3.69}	0.91 {3.19}	0.69 {2.41}
		-10	0.94 {3.29}	0.92 {3.22}	0.78 {2.74}	0.57 {2.02}
		-20	0.76 {2.67}	0.71 {2.50}	0.59 {2.08}	0.42 {1.48}
		-30	0.57 {2.01}	0.53 {1.85}	-	-
		-40	0.39 {1.37}	0.30 {1.07}	-	-
AEX-	2348BU	10	1.17 {4.11}	1.37 {4.80}	1.26 {4.44}	1.00 {3.53}
		0	1.14 {4.02}	1.18 {4.16}	1.04 {3.65}	0.80 {2.81}
		-5	1.04 {3.65}	1.05 {3.69}	0.91 {3.19}	0.69 {2.41}
		-10	0.94 {3.29}	0.92 {3.22}	0.78 {2.74}	0.57 {2.02}
		-20	0.76 {2.67}	0.71 {2.50}	0.59 {2.08}	0.42 {1.48}
		-30	0.57 {2.01}	0.53 {1.85}	-	-
		-40	0.39 {1.37}	0.30 {1.07}	-	-
AEX-	2341BU	10	1.53 {5.38}	1.79 {6.29}	1.66 {5.82}	1.32 {4.64}
		0	1.48 {5.20}	1.54 {5.41}	1.35 {4.75}	1.04 {3.65}
		-5	1.38 {4.86}	1.40 {4.92}	1.21 {4.25}	0.91 {3.21}
		-10	1.29 {4.53}	1.26 {4.42}	1.07 {3.76}	0.79 {2.77}
		-20	0.98 {3.45}	0.92 {3.24}	0.76 {2.68}	0.54 {1.90}
		-30	0.70 {2.45}	0.63 {2.22}	-	-
		-40	0.50 {1.77}	0.46 {1.60}	-	-
AEX-	2342BU	10	2.76 {9.70}	3.24 {11.4}	2.99 {10.5}	2.38 {8.38}
		0	2.69 {9.46}	2.79 {9.81}	2.46 {8.66}	1.89 {6.63}
		-5	2.47 {8.70}	2.50 {8.79}	2.17 {7.62}	1.63 {5.74}
		-10	2.26 {7.94}	2.22 {7.79}	1.88 {6.61}	1.38 {4.87}
		-20	1.78 {6.27}	1.68 {5.91}	1.38 {4.86}	0.98 {3.46}
		-30	1.32 {4.64}	1.21 {4.27}	-	-
		-40	0.90 {3.16}	0.80 {2.83}	-	-
AEX-	2344BU	10	4.55 {16.0}	5.35 {18.8}	4.95 {17.4}	3.92 {13.8}
		0	4.46 {15.7}	4.64 {16.3}	4.10 {14.4}	3.13 {11.0}
		-5	4.12 {14.5}	4.21 {14.8}	3.61 {12.7}	2.72 {9.55}
		-10	3.78 {13.3}	3.70 {13.0}	3.13 {11.0}	2.31 {8.11}
		-20	3.01 {10.6}	2.82 {9.93}	2.33 {8.19}	1.66 {5.83}
		-30	2.18 {7.65}	1.99 {7.01}	-	-
		-40	1.51 {5.32}	1.36 {4.77}	-	-
AEX-	4566BU	10	6.65 {23.4}	7.76 {27.3}	7.22 {25.4}	5.74 {20.2}
		0	6.34 {22.3}	6.57 {23.1}	5.80 {20.4}	4.46 {15.7}
		-5	5.94 {20.9}	5.97 {21.0}	5.18 {18.2}	3.90 {13.7}
		-10	5.52 {19.4}	5.37 {18.9}	4.55 {16.0}	3.38 {11.9}
		-20	4.32 {15.2}	5.20 {18.3}	3.36 {11.8}	2.37 {8.35}
		-30	3.21 {11.3}	2.90 {10.2}	-	-
		-40	2.28 {8.01}	2.05 {7.20}	-	-
AEX-	4568BU	10	9.10 {32.0}	10.6 {37.4}	9.87 {34.7}	7.85 {27.6}
		0	8.79 {30.9}	9.13 {32.1}	8.05 {28.3}	6.17 {21.7}
		-5	8.13 {28.6}	8.39 {29.5}	7.14 {25.1}	5.40 {19.0}
		-10	7.51 {26.4}	7.34 {25.8}	6.23 {21.9}	4.64 {16.3}
		-20	5.83 {20.5}	5.46 {19.2}	4.49 {15.8}	3.19 {11.2}
		-30	4.41 {15.5}	4.01 {14.1}	-	-
		-40	3.01 {10.6}	2.72 {9.55}	-	-

